



CERTIFICATE OF CONFORMITY

EU – LOW VOLTAGE DIRECTIVE – 2006/95/EC

Registration NO.: VT12119272

Applicant: WENZHOU LEIYUE ELECTRIC CO., LTD

Applicant Address: NO.1 XINGYE ROAD, DAGANG, BEIBAIXIANG TOWN, YUEQING CITY, ZHEJIANG, CHINA

Product Description: SURGE PROTECTIVE DEVICE

Model / Parameters: LY1, LY2, LY3, LY4, LY5, LY6, LY7, LY8, LY9
 I_{max}: 10KA, 15KA, 20KA, 30KA, 40KA, 50KA, 60KA, 80KA, 100KA, 120KA, 150KA I_{imp}: 10KA, 25KA, 35KA, 50KA, 80KA, 100KA, 120KA, 150KA U_n: DC24V, DC48V, DC110V, DC240V, DC500V, DC800V, DC1000V, DC1200V 1P, 2P, 3P, 4P(+NPE)

Complies with the requirements of the European Community Directive 2006/95/EC. The submitted products have been tested by us with the listed standards and found in compliance with the following European Standards:

EN 61643-11 : 2002 + A11 : 2007

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the License applicant's disposal. This certificate does not imply assessment of the series-production of the product. The CE markings as shown below can be affixed on the product after preparation of necessary technical documentation.



Authorized by:
Nov 09, 2012

Arnono T.
Chief Assessor



VOV CERTIFICATION & TESTING LABORATORY LIMITED

THIS CERTIFICATE REFLECTS THE FINDINGS OF THE TIME AND PLACE OF THE AUDIT
 THE CERTIFICATION IS ONLY VALID WITH THE TEST REPORT OR TECHNICAL CONSTRUCTION FILE
 Internet site: www.vov.org.uk E-mail: vov@vov.org.uk